Performance analysis of steam turbine in Thermal Power plant

Ramu Vasa 'Nirmal Ram A S, John Francis A, Karthick P,

Departmentof Mechanical Engineering ,

R.M.K. College of engineering and technology, Affiliated to Anna University R.S.M. Nagar, Puduvoyal - 601206, Tamil Nadu, India Corresponding author Email: ramnirmal05@gmail.com

Received 12 June 2018 Received in revised form 17 June 2018 Accepted 18 June 2018

ABSTRACT

The analysis of performance of the steam turbine has been carried out and the heat rate is calculated to find out the deviation between the design and the trend in the present operation condition so that the losses can be reduced in order to obtain better efficiency. Here we have calculated Gross Heat rate and Turbine cycle rate and also considered the losses in high energy drains. This analysis helped in predicting the turbine efficiency deterioration level and listed out the preliminary cause of deterioration.

Keywords — Heat rate, turbine performance, efficiency, Steam turbine, deterioration level.

I. INTRODUCTION

Steam turbine is the heart which plays a vital role in the power generation as it converts kinetic energy into mechanical energy. The efficiency is determined by the ability to convert all the input work into output work. However, in real case scenario this condition is not possible as most of the parts have friction and the work is dissipated in form of heat thereby producing only less than 50 percentage of the work it received as input energy. In this analysis, we have discussed how to overcome this efficiency gap and produce the maximum possible efficiency of the turbine. Here we have collected several working parameters and the actual efficiency of the turbine was calculated. By these calculations, we have characterised and suggested the improvement techniques to be opted to improve the efficiency of the turbine.

II. **PURPOSE**

Performance monitoring is performed to reduce the heat rate gaps which occurred over period of time and take corrective measures to reduce those gaps to improve the efficiency. Here we have identified and found out the heat rate deviations from the design data available. Then the cause(s) of heate rate gaps are identified by using fault trees or other resources. The equipment operators by their experience should be aware of equipment deterioration and suitable corrective action should be taken prior to impacts the heat rate. This type of pro-active approach should be accomplished by identifying key "primary process indicators". If this is done, the improvement in higherlevel performance parameters (heat rate, availability, etc.) will follow.

The purpose of monitoring primary process indicators is also to assist data validation/instrument



drift and its calibration need. By closely monitoring critical instruments, drifts or irregularities can be quickly identified and the instrument can be calibrated or replaced.

III. IDENTIFICATION OF PARAMETERS

List of parameters to be monitored, for the deviation is identified. The parameters which are utilised for the PG and routine tests are selected and then analysed. In most cases back pressure could be the major cause of heat rate degradation. Under rare case scenario back pressure could affect the units overall efficiency. Here deviation on account of HP and IP turbine goes unnoticed due to lack of feedback. So we have listed out the Effect of critical parameters on heat rate.

TABLE 1

Cı	ritical	para	ameters	for	perfor	mance	calculati	ion

aN			Effect on
S.No.	Parameter	Deviation	Heat
			Rate
1	Main Seam	-5 deg.C	+2.3
1.	Temp.		kcal/kWh
2	Main Steam	-1	+1
۷.	Press	Kg/cm ²	kcal/kWh
2	Reheat	-5 deg. C	+2.3
5.	Temperature		kcal/kWh
4	Reheat	+1% (MS	+3.0
4.	Spray	Flow)	kcal/kWh
	Condonson	. 1	+2.0
5.	Condenser De la Davia	+1	kcal/kWh
	Back Press	mmHg(a)	
6	HPT	1.0/	+4
0.	Efficiency	- 1 %0	kcal/kWh
7	IPT	1.0/	+3
1.	Efficiency	- 1 %0	kcal/kWh

8.	Excess O2	+1%	+7.2 kcal/kWh
9.	Flue Gas Temperature	+5oC	+4.6 kcal/kWh
10.	DM Make- up	+1%	+17 kcal/kW

•

IV. CYCLES USED IN STEAM TURBINE

Thermal power plant is working based on the principle of rankine cycle. The fuel used to transfer the thermal energy generated by combustion from boiler to turbine is water, which is vapour is and superheated in boiler (1-7) & re heater(8-9) and subsequently expanded in turbine (7-8 HP Turbine, 9-11 IP&LP Turbine) where it yields its thermal energy, producing the energy necessary to drive the generator. The exhaust steam is condensed in condenser (11-1)



Fig 1: Rankine cycle

The equipment through which water flows to do its work makes a closed circuit which is called thermal cycle. This equipment following the path of water is as follows.

1-2	Condensate Extraction Pump work		
2-3	Heat added in Low Pressure		
	Heaters		
3-4	Boiler Feeding Pump		
4-5	Heat added in High Pressure		
	Heater		
5-6	Boiler Drum		
6-7	Super Heater		
7-8	High Pressure Turbine		
8-9	Reheater		
9-10	Intermediate Pressure Turbine		
10-11	Low Pressure Turbine		
11-01	The exhaust steam is condensed in		
	condenser		

A. Types Of Blades:

Based on the application Blades are classified as follows

- 1) Pressure at stages
- HP BLADES (high pressure blades)
- IP BLADES (intermediate pressure blades)
- LP BLADES (low pressure blades)
- 2) Their function in the turbine Steam turbine moving blades
- Blades from the bar stock
- Rhomboid blades
- Curved blades
- Twisted profile blades
- Drawn profile blades

V. **OVERALL EFFICIENCY CALCULATION**

A. Mass flow rates

Feed water flow at HP Heater 7 Outlet

 $m_{14} \!=\! m_{10} \!+ m_{13} + m_9 \!- m_{20} \!- m_{21}$

$$\begin{array}{c} m_{14}\!=\!536\!\!+\!\!74.62\!\!+\!\!24.78\!\!+\!\!26.25\!\!+\!\!0.2\\ m_{14}\!=\!615.65\ kg/m^3 \end{array}$$

HP heater 6 Drain flow

 $m_{13}=m_{15}+m_{12}$

m₁₃

$$= 43.12 + 34.37$$

$$m_{13}=77.49 \text{ kg/m}^3$$

B. HP Heater 6, HP heater 7 steam flow

Heat balance around HP Heater 7

$m_{15}(h_{15}-h_{23}) = m_{14}(h_{14}-h_{24})$

 $m_{15} = m_{14}(h_{14}\text{-}h_{24})/(h_{22}\text{-}h_{23})$

$$m_{15} = 615.65*(1051.98 - 910.77312)/(3089 - 932.61)$$

$$m_{15} = 43.12 \text{ kg/m}^3$$

Heat balance around HP heater 6

$\mathbf{m}_{12}(\mathbf{h}_{12}\textbf{-}\mathbf{h}_{13}) = \mathbf{m}_{15}(\mathbf{h}_{13}\textbf{-}\mathbf{h}_{23}) + \mathbf{m}_{14}(\mathbf{h}_{25}\textbf{-}\mathbf{h}_{25a})$

$$\begin{split} m_{12} &= m_{14}(h_{25} - h_{25a}) + m_{15}(h_{13} - h_{23})/(h_{12a} - h_{13}) \\ m_{12} &= 673.19*(910.77 - 767.26) + 40.25(789.60 - 932.61)/(3356 - 789.60) \\ m_{12} &= 35.40 \text{ kg/m}^3 \end{split}$$

C. Deareator Steam flow



www.trendytechjournals.com

International Journal of Trendy Research in Engineering and Technology (IJTRET) Volume 2 Issue 3 June 2018

Heat balance around the deareator

$$\begin{split} \mathbf{m_{11}} \cdot \mathbf{h_{11}} = \mathbf{m_{10}} \cdot \mathbf{h_{10}} + \mathbf{m_{26}} \cdot \mathbf{h_{26}} + \mathbf{m_{13}} \cdot \mathbf{h_{13}} \\ \mathbf{m_{26}} = & (\mathbf{m_{11}} \cdot (\mathbf{h_{11}} \cdot \mathbf{h_{10}}) + \mathbf{m_{13}} \cdot (\mathbf{h_{10}} \cdot \mathbf{h_{13}})) / (\mathbf{h_{26}} \cdot \mathbf{h_{10}}) \\ \mathbf{m_{26}} &= & 536.34 * (751.06 - 932.61) + 789.604 * (932.61) \\ &- & 789.60) / (3167 - 932.61) \\ \mathbf{m_{26}} &= & \mathbf{6.95 \ kg/m^3} \end{split}$$

D. Spray water flow to auxiliary steam

Heat balance around the desuperheater

 $\mathbf{m}_{21} \cdot \mathbf{h}_{21} + \mathbf{m}_4 \cdot \mathbf{h}_4 = \mathbf{m}_{19} \cdot \mathbf{h}_{19}$ $\mathbf{m}_{19} = \mathbf{m}_{21} + \mathbf{m}_4$

 $m_{21} = (m_4. (h_4 - h_{19}))/(h_{19}-h_{21})$

 $m_{21} = 5*(3077 - 682.02) / (682.02 - 0)$

$m_{21} = 17.55 \text{ kg/m}^3$

Main steam flow

 $m_1 = m_{14} - m_8 - m_{Lboiler} - m_{LPH}$

 $m_1 = 614.89 + 0.76 + 0 + 0$

 $m_1 = 615.65 \text{ kg/m}^3$

Hot reheat mass flow to I.P. steam turbine inlet(m₅)

 $m_5 = m_3 + m_{21}$

 $m_3 = 563.77 + 0.2$

 $m_3 = 563.97 \text{ kg/m}^3$

E. Heat rate calculation

Heat rate={ $[(m_1*h_1)-(m_{14}*h_{14})+(m_3(h_5-m_3))+(m_3(m_5-m_$

 $h_3)) + (m_{21}(h_5 - h_{21})) + (m_7 * h_7) - (m_4 * h_4)] * 3600 \} / P_g \\ Heat rate = \{ [(615.65 * 812.47) - (615.65 * 251.43) + (563.77 * (843.57 - 742.87)) + (24.78 * (843.57 - 182.38)) \\ + (12.96 * 36.02) - (4 * 738.70)] * 3600 / 214.29 \}$

Heat rate = 2135.7 Kcal/KWhr

```
F. Total cycle efficiency
```

$\eta = P_g/\text{Heat supplied}$

```
\eta = 214.29 * 1000/493418
```

$$\eta = 43.429\%$$

VI. TYPICAL COST IMPLICATION OF 1 KCAL/KWH HR DEVIATION

GCV of coal : 2600 kcal/kg Coal cost : Rs 1950 per ton Plant load factor : 82% Load capacity : 210 MW Power Generation : 1508.47 MW = 1508,470,000 KWh (82% PLF)

1 kcal/kwh improvement in HR can save 1508,470,000 kcal in a year.

Coal saved in a year = 1508,470,000 kcal / 2600 kcal/kg = 580,180 kg/year (GCV 2600 kcal/kg) = **580.18 MT Coal = Rs 11,31,000** (Cost of coal = Rs 1950 / Tonne)



Fig 2: Gross turbine cycle heat rate vs Gross generated output

VII. PLANT PERFORMANCE INDICES: HEAT RATE

The heat rate of the coal fired power plant is the measure of efficient conversion of chemical energy in to electrical energy. If the power plant operates at 100% efficiency, the Heat rate will be 860 kcal/kwh. Currently, a state of art this power plant has a design heat rate od 2100 - 2200 kcal/kwh ie. About 39 to 41 percentage but in our analysis we get the heat rate of 38.2 prcentage so the gap in the heat rate loss will account in the efficiency.

VIII. **TURBINE EFFICIENCY GAP**

Typical values of efficiency

HP	86 %
IP	90 %
LP	80 %

LP Turbine efficiency is lower due to moisture content in last stages. 1% increase in moisture content effects 1% stage efficiency.

Table II List of turbine efficiency losses

Assumption : Frendv

www.trendytechjournals.com

International Journal of Trendy Research in Engineering and Technology (IJTRET) Volume 2 Issue 3 June 2018

IX.

Breakup of Turbine		
Efficiency Losses (%)		
Leakage loss	50%	
Surface roughness	36%	
Others	14%	

A. Turbine Surface roughness

- 1) Surface finish degradation:
- Deposits
- Corrosion
- Solid particle erosion
- Mechanical damage

Roughness upto 0.05 mm can lead to decrease in efficiency by 4%

Table III

Design Heat rate and actual Heat rate

Design freut fute und detudi freut fute				
Design	Actual	Total losses Kcal/kwh		
kcal/kwh	kcal/kwh			
1981	2135.7	154		

Accountable loss:127kcal/kwhUnaccountable loss:27 kcal/kwh

B. Accountable losses

Description	Loss in kcal/kwh
HP turbine Eff.	16
IP Turbine	31
efficiency	01
Cond. Vac.	32
HP. Heater	42
5 &6	.2
RH Temp	6

C. Unaccountable losses

Losses are nominal losses

- Passing through high energy drains.
- LP. Turbine performance.
- LP. Heaters.
- Uncertainity of Instruments.

TABLE IV

Typical losses

Typical Turbine/generator losses			
Nozzle and bucket	3.7%		
aerodynamic losses			
Exhaust losses	1.3%		
Turbine Pressure drop	0.2%		
Bearing and windage	0.2%		
Leakage	0.3%		
Generator electrical	6.1%		
losses			



www.trendytechjournals.com

FAULT ANALYSIS

In fault analysis carried out we came into conclusion that the heater tubes were fouled either in steam or water side as an effect of moisture content present in the steam and water.

There may be various internal leakages through the water box partition plate in the pipeline of the steam carry over tubes.

External leakages through by pass valve is the major problem as if there is more heat generated than the required amount then these are passed away through the bypass valves.

Plugged tubes and air blanketing is the major causes of reduction in the efficiency, as well as the pressurised sir and the high temperature drainage defects also contribute to the reduce in the efficiency.

X. CONCLUSION

A Performance analysis of Turbine in thermal power plant is carried out to emphasise on the efficiency. The results are analyzed for mass flow rates, temperature and pressure distributions on blades, power developed by stage and isentropic efficiency of the stage.

Under review, the analysis revealed that the average overall efficiency was 43.49% (43.13% minimum; 43.75 maximum) as against expected values of 44-45%.

The reasons for the lag in the insentropic efficiency of the turbine and overall power plant has been listed out. These include:

Drain Line Passing: This is a silent loss because it does not appear in parameters. Monitoring is done by temperature measurement on downstream (flash tank) side which is supposed to be cold.

Main Steam Pressure: Results into throttling loss.

Hot Reheat Temperature: Sometimes it is not possible to maintain hot reheat temperature due to variation in fuel calorific value and there is loss.

It is important to be the low cost power producer for the future generation. Power plant Engineers can make a significant contribution toward achieving this goal by implementing a well-organized performance monitoring program which will reduce fuel costs and facilitate cost-effective maintenance.

Uniform formats for performance reporting to generate a reliable database for cost effective maintenance and improvement to develop requise skills reducing the auxiliary unit power comsumption will also contribute the part in increasing the efficiency of the power plant.

Routine performance tests to be carried out with the special instruments duly calibrated and also testig with atmost precision can formulate the accurate results and there by reducing the unaccountable losses.

ACKNOWLEDGMENT

Support on demand, encouragement at the needed moment and guidance in the right direction are in dispensable for the success of any project. We have received these in excess from all corners from various people, we are glad to submit our gratitude to them.

We thank Shri.R.S.Munirathinam, Chairman, and Shri.R.M.Kishore, Vice Chairman of RMK group of Institutions for extending a generous hand in providing the best of resources to the college. Dr.T.Rengaraja, the esteemed Head of our Institution has been a source of motivation to all the staffs and students of our college. We are so much thankful to him. Our sincere thanks to Dr. S.BhagavathiPerumal, the Vice Principal for giving the continuous support for the completion of our project.

Our sincere thanks to Dr.M.Balasubramanian, the Head of the Department for his continuous support and motivation throughout our project.

We extend our profound gratitude to Mr.SenthilGavaskar our Project Coordinator and Mr.Vasa Ramu our Guide for his guidance, who has indeed been a polestar throughout the course of the project, we thank him for giving us full support to complete the project successfully.

Last, but not the least, we take this opportunity to thank all the staff members of the Department of Mechanical Engineering. Regards to our family, classmates and friends who offered an unflinching moral support for completion of this project.

REFERENCES

[1] ASME PTC PM-1993, "Performance Monitoring Guidelines for Steam Power Plants", American Society of Mechanical Engineers, 1993.

[2] ASME PTC 6-2004, "Performance Monitoring Guidelines for Steam Turbine", American Society of Mechanical Engineers, 2004.

[3] ASME PTC 6S-1988, "Procedures for Routine Performance Test of Steam Turbines", American Society of Mechanical Engineers, 1988. [4] R. Gay, "Power Plant Performance Monitoring", 1st ed., R-Squared Publishing, 2004.

[5] K. C. Cotton, "Evaluating and Improving Steam Turbine Performance," 2nd ed., Cotton Fact Inc., 1998, pp.332.

[6] S.Y. Kim "Data Collecting Method for Detection and On-time warning System of Industrial Process", Korea Patent, 1010967930000, Dec 14, 2011

[7]A handbook on the steam engine, with especial reference to small and medium-sized engines, for the use of engine makers, mechanical draughtsman, engineering students, and users of steam power (1902)

[8]http://archive.org/details/handbookonsteame00ha eduoft

[9]Thermal engineering by R.K. RAJPUT

[10] Center N S W. Handbook of reliability prediction procedures for mechanical equipment[M]. Carderock Division, Naval Surface Warfare Center, 1998

[11] Shijingyuan, Huxianyue. Some New Developments in the Research of Steam Turbine Strength[J]. ShangHai QiLunJi, 2002, (1): 1-6.

[12] Steele J. M., Lam T. C. T., Stress and Fatigue Analysis of Steam Turbine Blades with ANSYS[C]//ANSYS Conference. 1993.

[13] S. Park and G. Heo, "Simulation Based Data Reconciliation for Monitoring Power Plant Efficiency," Transactions of the Korean Nuclear Society, Jeju, Korea, Oct 21-22, 2010.

[14] S. Simani and C. Fantuzzi, "Fault Diagnosis in Power Plant using Neural Networks", Information Sciences, Vol. 127, pp. 125-136, 2000.

[15] J. Hines and A. Usynin, "Current Computational Trends in Equipment Prognostics," International Journal of Computational Intelligence Systems, Vol. 1, No. 1, pp. 94–102, Jan. 2008.

[16] J.B. Coble, P. Ramuhalli, L.J. Bond, J.W. Hines, B.R. Upadhyaya, "Prognostics and Health Management in Nuclear Power Plants: A Review of Technologies and Applications", U.S. Department of Energy, PNNL-21515, July 2012.

[17] Rainer Quinkertz *et al.*, (2010), "High

Efficiency Stem Turbine Packages for

Concentrated Solar Power Plants".

[18] Stanley Schurdak (2012), "Steam Turbine

Blade Design", *Conference Session b6*,

2214, Twelfth Annual Freshman Conference.

[19] Sundranayagam *et al.*, (2001), "The Effect of the Variation of Axial Velocity Incom-pressible Flow Through a Cascade of Aerofoils", Vol. 130, No. 02, pp. 1019.

[20] Vivek Asthana (2008), "Performance of

Power Plants with High Temperature Conditions at Sub-critical Pressures", 5th European Thermal-Sciences Conference, The Netherlands.

[21] Beebe, R (2005) Submitted for publication in Journal of Quality in Maintenance engineering



Derivation of performance correction factors by test for condition monitoring of steam turbines
[22] Kearney, PJ; Hogg, SI; Brown, RD (2004)
Performance guarantee and testing of steam turbine retrofits Proceedings of ASME POWER 2004
[23] Lo, KL and Abdullah, H (2001) Condition monitoring of turbines for power plants Universities
Power Engineering Conference, Swansea

Biographies and Photographs

Ramu Vasa did his schooling in Board of Intermediate at Andhra Pradesh and continued his bachelor of engineering education in Mechanical in Jawaharlal Nehru Techonological university and further pursued his masters degree in engineering design in Anna University. Then he started working in ST. Peters engineering college at 2008 to 2011. Finally now he is working in RMK College of engineering and technology as Assistant Professor.

Nirmal Ram A S was born in Chennai. After completing high school in ONGC public school, Karaikal, Pondicherry district. Continued higher secondary school in the same mentioned above. He is currently pursuing B.E. degree in Mechanical engineering at R.M.K college of Engineering and technology in Chennai puduvoyal district. Has undergone many internship training in various reputed companies such as ONGC, Ashok Leyland, Chennai Ford, Rane brake India LTD.

